

Our Ref: 3em P2024-030 - Compliance Letter Rev_1
Date: 21 February 2025



MCG Architects
62 Wittenoom Street
Bunbury
WA, 6230

Attention: Mr D Robertson

Dear Desmond

**WAROONA COMMUNITY PRECINCT BIG SHED
ELECTRICAL CONSULTING SERVICES**

3em Engineering Consultants confirms the design as detailed on the Waroona Community Precinct Big Shed electrical services documentation package(drawing number(s):

- P2024-030 E000_0
- P2024-030 E100_0
- P2024-030 E200_0
- P2024-030 E300_0
- P2024-030 E400_0

Complies with the relevant sections of the Building Code of Australia (BCA) and referenced Australian Standards (AS) as follows :-

- BCA - Part E4.2 and 4.8 – Emergency Lighting, Exit Signs
- BCA - Part F4.4 – Artificial Lighting
- BCA - Part J6 – Artificial Lighting & Power
- AS 2293.1 – Emergency lighting and Exit signage
- AS 1680.0 – Artificial lighting

Yours sincerely

A handwritten signature in black ink, appearing to be 'Deon Keet', written over a light blue circular stamp.

DEON KEET BEng (Hons 1st), Electrical Engineering, (MIEAust, NER 3493779)

Director
On Behalf of 3em Engineering Consultants

3em Engineering Consultants

Perth, WA, 6069

T +61 4 99 99 21 91 | E deon@3emconsultants.com | ABN: 39 890 419 565